

ZESTAWIENIE OPRAW PROJEKTOWANYCH – BUDYNEK GŁÓWNY

BUDYNEK GŁÓWNY WOJEWÓDZKIEJ KOMENDY W POZNANIU		PRZYZIEMIE	PARTER	PIĘTRO I	PIĘTRO II	PIĘTRO III	PIĘTRO IV	PIWNICA 1	PIWNICA 2	RAZEM	MOC JEDNOSTKOWA	MOC ŹRÓDEŁ ŚWIATŁA (W)
A1	AQUF2 2x35W HF IP65	-	-	1	-	-	-	-	6	7	70	490
A2	CORRF2 2x49W Hf IP65	-	8	-	-	-	-	-	-	8	98	784
A3	CORRF2 2x28W Hf IP65	-	2	-	-	-	-	-	-	2	56	112
A4	AQUF2 2x28 HF IP65	-	-	-	-	-	-	-	4	4	56	224
B1	CHALICE 190C 2x26 HF	49	29	20	21	7	13	-	-	139	52	7228
B2	CHALICE 190 2x26 HF	51	57	59	66	77	27	-	-	337	52	17524
B3	CHALICE 190 1x26 HF	7	-	-	-	-	-	-	-	7	26	182
C1	CETUS 2x18W FR	-	-	2	-	-	-	-	-	2	36	72
C2	CETUS 2x26W FR	-	29	-	-	-	-	-	-	29	52	1508
E1	POPPACK 1x35W HF	4	-	12	10	12	-	-	26	64	35	2240
E2	POPPACK 1x28W HF	1	-	-	-	-	-	-	8	9	28	252
I1	IQ 2x55W HF MPHF	6	23	91	33	-	-	-	-	153	110	16830
M1	CIMI 1x14W HF IP44	8	-	-	-	-	-	-	1	9	14	126
M2	CIMI 1x28W HF IP44	1	-	-	-	-	-	-	-	1	28	28
O1	OPTUS IV 2x35W DMB IP23	12	-	-	-	-	-	-	-	12	70	840
P1	PRISMA 2x28W OP IP44	12	9	12	10	12	7	-	12	74	56	4144
P2	PRISMA 2x14W OP IP44	13	-	-	-	-	-	-	34	47	28	1316
T1	PUNCH II 2x28 HF DMB	54	60	59	100	117	38	-	-	428	56	23968
T2	PUNCH II 2x35 HF DMB	68	73	66	66	93	50	-	-	416	70	29120
L1	LS2 LED 8,5W IP65	2	-	-	-	-	-	-	-	2	8,5	17
RAZEM												106988